

QUARTERLY INSPECTION – FUEL STORAGE AREAS

Inspector: _____ Fueling Agent: _____ Date: _____

S – Satisfactory U – Unsatisfactory R – Remark Below	Jet A Section			100LL Section			Other _____		
	S	U	R	S	U	R	S	U	R
Fencing/Locks/Signs									
Piping protected from vehicles									
No Smoking Signs posted									
Deadman Controls for loading stations									
2 Fire Extinguishers – Inspected/Accessible									
Boldly Marked Emergency Cutoffs - Location									
No Fuel Leaks									
Bonding wire/clips at loading stations/operable									
Piping/Pumps bonded and grounded									
No vegetation or materials to spread fire									
No evidence of Smoking									
Hoses in good condition									
Explosion Proof Electrical Equipment									

Remarks: _____

